



# Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 1 of 6

DECNO GROUP LIMITED

LONGQUAN ROAD, ZHANGQIU, JINAN, SHANDONG, CHINA

Sample Description : SPC FLOORING, RIGID CORE FLOORING  
 \*\*\*\*\*  
 Sample Receiving Date : JUN. 04, 2019  
 Testing Period : JUN. 04, 2019 TO JUN. 26, 2019  
 Test Performed : SELECTED TEST(S) AS REQUESTED BY APPLICANT  
 Test Requested : SELECTED TEST(S) AS REQUESTED BY APPLICANT  
 Test Result(s) : FOR FURTHER DETAILS, PLEASE REFER TO THE  
 FOLLOWING PAGE(S)  
 Conclusion : THE TEST DATA WERE PROVIDED TO CLIENT FOR  
 THEIR OWN ANALYSIS.

Signed for and on behalf of  
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.



Melody Zhang  
Authorized Signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
 Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)  
 4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District, Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
 中国·上海·徐汇区宜山路889号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

# Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 2 of 6

## Test Conducted:

### Marking and Labelling (EN 14041:2004 / AC: 2006 Clause 6)

Test Property	Test procedure/requirements	Rating/ Result
Marking and Labelling Clause 6	Products which conform to the requirements of this document shall be clearly and indelibly marked by the manufacturer either on their package or on an adhesive label with the following information: a) the number and the year of this European Standard, i.e. EN 14041:2004; b) the manufacturer's or supplier's identification; c) the product name and batch number (possibly in code form).	Pass



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

SGS-CSI (Shanghai) Technical Services (Shanghai) Co., Ltd. 4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District, Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
 中国·上海·徐汇区宜山路889号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

## Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 3 of 6

### Sample Photo:

Test sample



Artwork of Label provided by client

<b>DECNO<sup>TM</sup></b>	
Product:	SPC Flooring Rigid Core Flooring
Standard:	EN 14041:2004/AC:2006
Manufacturer:	DECNO GROUP LIMITED
Website: <a href="http://www.decnoflooring.com">www.decnoflooring.com</a>	



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

SGS-CSI (Shanghai) Technical Services (Shanghai) Co., Ltd. 4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
 中国·上海·徐汇区宜山路289号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

# Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 4 of 6

Test item: Dynamic coefficient of friction

Test Method: EN 13893:2002

Test condition:

Specimen dimension: 1000mm×288mm

Testing surface: front side

Testing speed: 0.20m/s


Test Result:

Dynamic coefficient of friction:

X Direction: 0.31

Y Direction: 0.33

Specimen photo(s):



Note: The test was performed by SGS-CSTC Standards Technical Services Co., Ltd. Xiamen Branch Testing Center.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
 Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)  
 SGS-CSTC Standards Technical Services Co., Ltd. 4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
 中国·上海·徐汇区宜山路289号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

# Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 5 of 6

Test Part Description :

Specimen No.	SGS Sample ID	Description
SN1	SHA19-126517.001	Grey plastic board with black with wooden cover

Remarks :

- (1) 1 mg/kg = 0.0001%
- (2) MDL = Method Detection Limit
- (3) ND = Not Detected ( < MDL )
- (4) "-" = Not Regulated

**Entry 22 of Regulation (EC) No 552/2009 amending Annex XVII of REACH Regulation (EC) No 1907/2006- Pentachlorophenol (PCP)**

Test Method : With reference to LFGB § 64 BVL B 82.02.8 - 2001, analysis was performed by GC-ECD or GC-MS.

Test Item(s)	Limit	Unit	MDL	001
Pentachlorophenol (PCP)	1000	mg/kg	0.5	ND
<b>Conclusion</b>				<b>PASS</b>

**Formaldehyde Emission**

Test Method : With reference to EN 717-1:2004, analysis was performed by UV-Vis.

Test Item(s)	Unit	MDL	001
Formaldehyde Emission (In air)	mg/m <sup>3</sup>	0.080	ND

Notes :

The reported result is for reference only.

Remark:

- Since the data and / or information above division line of front page is provided by the applicant, the relevant results or conclusions of this report are only made for these data and / or information, SGS is not responsible for the authenticity, integrity and results of the data and information and / or the validity of the conclusion. Testing results only apply to the sample as received.
- The declaration of conformity is only based on the actual value of laboratory activity, measurement uncertainty of the results not take into account.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
 Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)  
 4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
 中国·上海·徐汇区宜山路289号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

## Test Report

No.: SHHL1906029149FB

Date: JUN. 26, 2019

Page: 6 of 6

### Sample Photo:



**SHAHG1912651701**

SGS authenticate the photo on original report only

\*\*\*End of Report\*\*\*



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

4<sup>th</sup> Building, No.289, Yishan Road, Xuhui District, Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6399 www.sgs.com.cn  
中国·上海·徐汇区宜山路289号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6399 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

# SGS Test

SGS international authoritative standard inspection organization

SGS certification means a compliance certification conducted by SGS to targets based on standard, regulations, customer requirements, etc. Inspection, detection, authentication, certification, etc. must be conducted before relevant certification.



Wechat



Website

Tel: +86-400-110-0010  
Web: [www.decnofloorings.com](http://www.decnofloorings.com)  
Email: [sales@decnoflooring.com](mailto:sales@decnoflooring.com)  
Whatsapp/Wechat: +8617736066787